



# Devon & Somerset Fire Protection Ltd

1 Tyne Park Blackbrook Taunton  
Somerset TA1 2RP  
Tel 01823 322925  
Mobile 07786 723432



## Certificate of Extinguisher Maintenance

### Customer

Catherine Bass  
Cadbury House  
Fore Street  
Culmstock  
Devon EX15 3JD

### Service Address

Culmstock Village Hall  
Culmstock  
Devon

This certificate confirms that we have completed the maintenance service of the fire equipment listed below in accordance with BS 5306-3:2009

Water 4

Co2 1

Foam

Hose

Powder 2

Wet Chemical

**Certificate Number** C15923 a

**Issue Date** 17/10/2025

Signed *R. Smith*

Signed

*Russell Smith: DSfire*

*Owner or responsible person*

Routine Inspection by the user: BS 5306-3:2009

The user or user's representative should carry out regular visual inspection of all equipment to make sure that:

- a) Each extinguisher is located in the designated place:
- b) Each extinguisher is unobstructed and visible:
- c) The operating instructions of each extinguisher are clean and legible and face outwards:
- d) Each extinguisher has not been operated and is not obviously damaged:
- e) The reading of any pressure gauge or indicator fitted to an extinguisher is within operational and safety limits:
- f) The seals and tamper indicators of each extinguisher are not broken or missing:

The user should arrange for corrective action, where necessary.

**Devon & Somerset Fire Protection Ltd:**  
**A British Fire Consortium Audited Company**  
**Established 1991**

Please Note: Equipment unfit for service listed overleaf!