



Devon & Somerset Fire Protection Ltd

5, Thomash Close Monkton Heathfield
Taunton, Somerset, TA2 8PQ
Tel 01823 322925 sales & servicing

Certificate of Extinguisher Maintenance

Customer
Catherine Bass
Cadbury House
Fore Street
Culmstock
Devon EX15 3JD

Service Address
Culmstock Village Hall
Culmstock
Devon

This certificate confirms that we have completed the maintenance service of the fire equipment listed below in accordance with BS 5306-3:2009

Water 4	Co2 1
Foam	Hose
Powder 2	Wet Chemical

Certificate Number C13081

Issue Date 01/11/2021

Signed

Colin Smith: DSfire

Signed

Owner or responsible person

Routine Inspection by the user: BS 5306-3:2009

The user or user's representative should carry out regular visual inspection of all equipment to make sure that:

- Each extinguisher is located in the designated place;
- Each extinguisher is unobstructed and visible;
- The operating instructions of each extinguisher are clean and legible and face outwards;
- Each extinguisher has not been operated and is not obviously damaged;
- The reading of any pressure gauge or indicator fitted to an extinguisher is within operational and safety limits;
- The seals and tamper indicators of each extinguisher are not broken or missing;

The user should arrange for corrective action, where necessary.

**Devon & Somerset Fire Protection Ltd:
A British Fire Consortium Audited Company
Established 1991**

Please Note: Equipment unfit for service listed overleaf!